


# Low Cost Wind Energy: Comparing Distant Wind Resources to Local Resources

David Hoppock

Dalia Patino Echeverri, PhD

**Climate Change Policy Partnership**

Duke University




# Policy Drivers: RPS



## Renewable Portfolio Standards

[www.dsireusa.org](http://www.dsireusa.org) / January 2010



# Why Wind?

- **Widely available**
- **Fastest growing renewable resource**
- **Low cost**

## **EIA AEO 2009 Overnight Construction Costs**

Onshore Wind	\$1932/kW
Offshore Wind	\$3851/kW
Solar Thermal	\$5021/kW
Solar PV	\$6038/kW
Geothermal	\$1711/kW*
Biomass	\$3766/kW

\*Dry stream plant - limited availability



# Barriers to Wind

## Transmission

- **Best wind far from population centers**
- **Permitting, siting, cost allocation of long distance transmission is very difficult**
  - **>300 GW wind in transmission queues**
  - **Curtailment at existing wind farms**



# Objective: Determine lowest cost wind resource to meet Illinois RPS

**Costs: Capital cost of new wind & transmission**

## Assumptions

- Requires new transmission
- Capacity factor fully characterizes wind
  - O&M, integration, wholesale prices unchanged
- Demand source is major substation outside of

**Chicago**




# Distant vs. Local Wind Resources


**Distant wind resources have higher capacity factors,  
lower wind capital costs**

**Local wind resources require less transmission,  
reducing transmission capital costs**


**Trade off: wind CC vs. transmission CC**



# Potential Wind Sites: NREL Eastern Wind Integration Study (EWITS)




# Potential Wind Sites, cont.





# Four Wind Distance Capacity Factor Categories

- 1. Reference wind 36% CF, 50 km from load, 100 m IEC Class 3 turbine**
- 2. 39.5% CF, 550 km from load, 80 m IEC Class 2**
- 3. 41% CF, 650 km from load, 80 m IEC Class 2**
- 4. 42% CF, 750 km from load, 80 m IEC Class 2**




# Wind Installed Capital Cost

## *DOE 2008 Wind Technologies Market Report*

- **2009 estimate \$2,120/kW**
- **2007-2008 Midwest average \$1,913/kW**

**100 m IEC Class 3 wind turbines (Reference wind)**

**installed capital costs 14% higher**




# HVAC & HVDC Transmission Capital Cost Estimates

## Reviewed transmission planning documents

- **Midwest ISO Transmission Expansion Plan**
- **Other transmission planning documents**

**HVDC cost estimates are difficult to obtain**




# Comparison Metrics

**Lowest Cost Wind Resource (\$/kWh) by Delivered Energy**


**Lowest Cost Wind Resource (\$/kWh) by Installed Capacity**

**Breakeven Capacity: Turbine capital cost savings = Capital cost of additional transmission**

**→ Compare to transmission capacity**



# Lowest Cost Wind Resource (\$/kWh) by Delivered Energy



# Discussion

For high CC estimates, up to 9,000 GWh/year,  
reference wind is low cost – 2.9 GW

For low CC estimates, up to 4,000 GWh/year,  
reference wind is low cost – 1.3 GW

Largest wind farm: 781 MW

Ave. development in U.S. (2008): 83 MW

Low cost option for short term RPS requirement is  
local wind




# Discussion

Low cost option for long term RPS requirements is distant wind, *if economies of scale are feasible*

- 1.2 GW distant wind farm producing ~4,000 GWh/yr (39.5% CF, 550 km) \$3-\$3.6 billion
- Does not include increased risk


*Large scale investment in distant high quality wind resources will not occur without policies to remove obstacles to transmission expansion*



# Lowest Cost Wind Resource (\$/kWh) by Installed Capacity

Installed Capacity (MW)	High Transmission & Wind Capital Cost Estimate				Low Transmission & Wind Capital Cost Estimate			
	Lowest Cost Wind Resource	\$/kWh	Transmission voltage kV	Transmission constrained CF	Lowest Cost Wind Resource	\$/kWh	Transmission voltage kV	Transmission constrained CF
100	Reference	\$ 0.100	230	36.0%	Reference	\$ 0.085	230	36.0%
200	Reference	\$ 0.095	230	36.0%	Reference	\$ 0.083	230	36.0%
300	Reference	\$ 0.093	230	36.0%	Reference	\$ 0.082	230	36.0%
400	Reference	\$ 0.095	230	35.1%	Reference	\$ 0.084	230	35.1%
500	Reference	\$ 0.960	345	36.0%	Reference	\$ 0.084	345	36.0%
600	Reference	\$ 0.094	500	36.0%	Reference	\$ 0.084	500	36.0%
700	Reference	\$ 0.094	500	36.0%	Reference	\$ 0.084	500	36.0%
800	Reference	\$ 0.093	500	36.0%	Reference	\$ 0.083	500	36.0%
1000	Reference	\$ 0.093	500	36.0%	Reference	\$ 0.083	500	36.0%
1200	Reference	\$ 0.092	500	36.0%	Reference	\$ 0.083	500	36.0%
1400	Reference	\$ 0.092	500	36.0%	39.5%	\$ 0.081	765	39.5%
1600	Reference	\$ 0.092	500	36.0%	39.5%	\$ 0.079	765	39.5%
1800	Reference	\$ 0.091	500	36.0%	39.5%	\$ 0.078	765	39.4%
2000	Reference	\$ 0.091	500	36.0%	39.5%	\$ 0.079	765	38.5%
2500	42%	\$ 0.091	HVDC	42.3%	42%	\$ 0.077	HVDC	42.3%
3000	42%	\$ 0.087	HVDC	42.3%	42%	\$ 0.074	HVDC	42.3%
3500	42%	\$ 0.086	HVDC	41.5%	42%	\$ 0.074	HVDC	41.5%
4000	42%	\$ 0.088	HVDC	39.4%	42%	\$ 0.078	HVDC	39.4%

**Note: Sometimes efficient to undersize transmission**





# Breakeven capacity


For each wind class, there is a breakeven capacity where:

Turbine capital cost savings = Capital cost of additional transmission


Compared to reference wind resource – 36% CF wind requiring 50 km new transmission




# HVAC & HVDC Transmission Power Transfer Capacity



# 765 kV Transmission Break Even Capacities



# 500 kV HVDC Transmission Break Even Capacity



# HVAC & HVDC Transmission Capital Cost Estimates

	115 kV	230 kV	345 kV	500 kV	765 kV	500 kV HVDC
High Estimate	\$590,000/mi	\$910,000/mi	\$2,730,000/mi	\$2,200,000/mi	\$3,200,000/mi	\$3,000,000/mi
Middle Estimate			\$1,700,000/mi	\$1,910,000/mi	\$2,170,000/mi	\$1,960,000/mi
Low Estimate	\$210,000/mi	\$300,000/mi	\$1,370,000/mi	\$1,500,000/mi	\$2,000,000/mi	\$1,700,000/mi
Source	MTEP08	High: MTEP08 Low: LBNL	MTEP08	High & Low: LBNL Mid: SPP EHV Overlay	High & Low: LBNL Mid: SPP EHV Overlay	High: LBNL Mid: Gateway South Low: WREZ

MTEP 08: *Midwest ISO Transmission Expansion Plan 2008*

LBNL: Lawrence Berkeley National Laboratory, *The Cost of Transmission for Wind Energy: A Review of Transmission Planning Studies*

SPP EHV Overlay: *Updated Southwest Power Pool EHV Overlay Study*

Gateway South: *Gateway South and Transwest Express Conceptual Technical Report*

WREZ: *Western Renewable Energy Zones Generation & Transmission Model*

**HVDC converter \$250 million (3000 MW)**



# Potential Wind Sites

## NREL Eastern Wind Integration Study (EWITS) sites

